

測試報告

報告編號： US/2018/90369

日期： 2018年10月01日

頁數： 1 of 2



漢泰先進材料股份有限公司

苗栗縣竹南鎮友義路66號2樓

以下測試之樣品係由申請廠商所提供及確認：

樣品名稱： W-E2 (20%BCS+14%H2O2+66%H2O)

申請廠商： 漢泰先進材料股份有限公司

取樣日期/位置： 2018年09月18日/漢泰公司

送樣日期： 2018年09月19日

測試日期： 2018年09月19日 ~ 2018年10月01日

測試結果：

測試項目	CAS NO.	測試方法	測試結果	定量極限/ 偵測極限	單位
閃火點	---	本測試參考ASTM D92方法檢測。	>92*	---	°C

備註：1. 本報告不得分離，分離使用無效。

2. 若該測試項目屬於定量分析則以「定量極限」表示；若該測試項目屬於定性分析則以「偵測極限」表示。

3. 低於定量極限之測定值以 "N.D." 表示；低於偵測極限之測定值以 " 陰性 " 表示。

4. "*"在92°C時點火器熄火，92°C以下無閃火。

5. 本次委託測試項目由SGS化學實驗室-台中執行。

-END-

Signed for and on behalf of

SGS Taiwan Ltd.

Shin-Jyh Chen

Shin-Jyh Chen

Manager



測試報告

報告編號： US/2018/90369

日期： 2018年10月01日

頁數： 2 of 2



漢泰先進材料股份有限公司
苗栗縣竹南鎮友義路66號2樓

樣品照片



This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.